

Scope of Work for Scheduled Outages on SGen-1000A

			Medium	Major
Equipment (KKS)	Activity			
1 Medium Inspection				
2 Major Inspection				
A) Outer Enclosure				
Visual inspections:				
	Enclosure for water leaks		x	x
	Ambient air filters (replace if required)		x	x
	Inner lights		x	x
	External foundation gaskets of enclosure's differential pressure duct		x	x
	Foundation varnish		x	x
	Foam gaskets between foundation and bedplate		x	x
B) Stator (MKA)				
Electrical tests:				
	Measure insulation resistances of each phase of stator winding		x	x
	Through bolt insulation resistance test, if accessible without additional disassembly of major components			x
	Resistance temperature detector or thermo couple insulation resistance test		x	x
	Evaluate condition of insulation		x	x
Mechanical tests:				
	Check foundation bolt gaps (if Generator is not grouted)		x	x
	Check foundation bolt torque (if Generator is grouted and hard bolted to the foundation)		x	x
	Fixator torque (if Generator is not grouted)		x	x
Visual inspections:				
	Stator core condition by robotic tool		x	x
	Ventilation paths of core by robotic tool		x	x
	Condition of fixators and grout		x	x
	Thermocouple and resistance temperature detector (RTD)-cables and seals			x
	Bushings and adjacent component		x	x
	P-Seal / Core seal condition		x	x

			Medium	Major
1	Medium Inspection			
2	Major Inspection			
Equipment (KKS)	Activity			
	Stator winding conditions		X	X
	Maintenance:			
	Replacement of all dismantled gaskets		X	X
	Check / replacement of O-rings/ gaskets (depending on design)			X
C) Terminal bushing (MKA)				
	Replacement of all gaskets to casing, internal gaskets and O-Rings (depending on design)			X
	Electrical test:			X
	Inspect top & bottom surface of ISO-phase adapter plate (as far as possible)		X	X
D) Rotor (MKA)				
	Electrical tests:			
	Measure insulation resistance of rotor winding		X	X
	RSO measurement		X	X
	Mechanical tests:			
	NDE of rotor blades		X	X
	Visual inspections:			
	Blower blades		X	
	End winding area		X	X
	Bearing journals		X	X
	Shaft seal contact surface		X	X
	Grounding brushes and shaft contact surface		X	X
	Rotor wedges and retaining rings*		X	X
	Rotor slot ventilation paths by robotic tool		X	X
	Flex slots and rotor teeth at wedge-to-wedge gaps by robotic tool		X	X
	Balance weights in pole by robotic tool		X	X
	*NDE of the rotor retaining rings (e.g. by robotic tool) in addition to the visual inspection.			
	Maintenance:			
	Replacement of bolts and locking device for any rotating component removed		X	X
E) Cooler (MKA)				
	Mechanical tests:			
	Valves at vent pipes (function)		X	X
	Valves at drain pipes (function)		X	X
	Perform leakage / tightness test			X
	Visual inspections:			

		Medium	Major
1 Medium Inspection			
2 Major Inspection			
Equipment (KKS)	Activity		
	Condition of coolers and water boxes acc. to contamination and corrosion	x	x
	Condition and function of temperature measuring devices	x	x
	Condition and function of pressure measuring devices	x	x
	Cooling water inlet and outlet pipes	x	x
	Mounting of all coolers	x	x
	Cooler tubes surface for damages	x	x
	Maintenance:		
	Replacement of O-Rings and header gaskets		x
F) Bearings (as far as possible and depending on design) (MKD)			
	Electrical tests:		
	Bearing insulation	x	x
	Function of bearing temperature measuring device	x	x
	Mechanical tests:		
	Bearing surfaces and babbitt bonding	x	x
	Bearing clearances	x	x
	Seating of bearing sleeves on bearing saddles		x
	Clearance of labyrinth rings and seal strips	x	x
	Function of lift oil components	x	x
	Functional check of actual shaft lift	x	x
	Visual inspections:		
	Lift oil grooves	x	x
	Condition of bearing temperature measuring device	x	x
	Condition of lift oil hoses		
	Condition of wiring and connections	x	x
	Labyrinth rings	x	x
	Maintenance:		
	Replacement of lift oil hoses	x	x
G) Slip Rings (MKC) (if implemented)			
	Electrical tests:		
	Insulation resistance of slip rings	x	x
	Measure insulation resistance of collector stationary rigging	x	x
	Mechanical tests:		
	Performance of brush carrier and carbon brushes	x	x
	Check brush holder alignment and radial clearances	x	x
	Visual inspections:		
	Condition and performance of measuring devices	x	x
	Condition of brush carrier and carbon brushes	x	x
	Condition of slip rings / insulation	x	x

			Medium	Major
1	2			
Medium Inspection	Major Inspection			
Equipment (KKS)	Activity			
	Blower and assembly hardware			X
	Collector exhaust housing		X	X
	Labyrinth rings			X
Maintenance:				
	Replacement of air filter			X
G) Integral Brushless Exciter (MKC) (if implemented)				
Electrical tests:				
Diode Wheel	Diode forward / reverse resistance		X	X
	Diode wheel to heat sink insulation resistance			X
Main exciter rotor	Ground detection ring insulation resistance (as far as possible)		X	X
Main exciter stator	AC impedance & pole balance test		X	X
	Winding insulation resistance		X	X
Visual inspections:				
	Labyrinth rings			X
	Exciter and diode wheel condition		X	X
Maintenance:				
	Replacement of filter			X
H) Generator Supervisory Equipment (MKA)				
	Condition and performance of temperature gauges and alarms		X	X
	Replacement of gaskets at temperature measuring points			X
	Condition and performance of liquid level alarm switches		X	X
	(Pedestal) vibration device functional test		X	X

1 Medium Inspection				
2 Major Inspection				
Equipment (KKS)	Activity		2 Medium	3 Major
Re-commissioning				
Cold Re-commissioning				
	Check for cleanness (inside and outside generator)		x	x
	Plausibility check of generator temperature measuring device		x	x
Hot Re-commissioning				
	Check the connection of lube oil and lift oil pipes to generator		x	x
Optimization				
	Measure shaft voltage and shaft current if generator is on load		x	x
	Final adjustment of all systems on load		x	x
	Check all operating values local and in I&C		x	x
	Record of operating values (different load)		x	x
